

- 1. FOR USE IN AREAS WHERE THERE IS SIDEWALK SEPARATED FROM THE BACK OF CURB BY 24" OR MORE, OR WHERE IT IS EXPECTED THAT SIDEWALK WILL BE ADDED IN THE FUTURE.
- 2. WHEN AN EXISTING ENTRANCE IS LESS THAN 20' IN WIDTH A UNIFORM TAPER SHALL BE CONSTRUCTED TO TIE INTO THE EXISTING ENTRANCE AS DIRECTED BY THE ENGINEER.
- 3. EXPANSION JOINT MATERIAL TO BE INSTALLED IN ACCORDANCE WITH STD. MD-655.01.
- 4. WHERE 60" SIDEWALK CAN NOT BE PROVIDED. 36" MIN. MAY BE USED AS LONG AS PASSING ZONES ARE PROVIDED IN ACCORDANCE WITH STD. MD-655.02.

| SPECIFICATION   | CATEGORY CODE ITEMS         |  | Maryland Department of Transportation   |
|---|-----------------------------|--|---|
| APPROVED KILG. MECALL  DIRECTOR - OFFICE OF HIGHWAY DEVELOPMENT |                             |  | STATE HIGHWAY ADMINISTRATION STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES |
| StateHighway  | APPROVAL • SHA<br>REVISIONS | APPROVAL • FEDERAL<br>HIGHWAY ADMINISTRATION | STANDARD ENTRANCE CONSTRUCTION RESIDENTIAL & COMMERCIAL METHOD NO.2           |
|   | APPROVAL 2-10-04 REVISED    | APPROVAL 3-31-04 REVISED                     |   |
|   | REVISED<br>REVISED          | REVISED<br>REVISED                           | STANDARD NO. MD 630.02  |